


# High-Voltage Supply Requirements Review



September 16, 2003

Nobuyoshi Kitamura

University of Wisconsin-Madison / SSEC

# Requirements Update


- ❑ Changes / clarification as a result of recent **engineering** work
  - ➔ Remove “split ground” requirement
- ❑ Changes in response to the **PDR** (5/20/2003)
  - ➔ PMT pulse-coupling transformer specifications change (Proposed)
  - ➔ Require conformal coating on PMT Base Board (Proposed)
- ❑ Changes as a result of baseline change (Iseg ➔ **EMCO**)
  - ➔ Single-board to two-board
  - ➔ Fixed to scaled 1<sup>st</sup> dynode voltage

## Design / Specification Review

- ❑ PMT HV Base Board (“passive base”)
- ❑ HV Control Board
- ❑ HV Generator


# Requirements Update

# Documentation



\*George Anderson has been maintaining these documents.

# Change due to Engineering Evaluation




## Delete: 3.2.2.5.3 Split Power/Digital and Analog Grounds

- Iseg has been unable to implement this requirement  
(The trial version has major functional problems)
- Noise levels are acceptable w/o this requirement
- The split-ground requirement does not apply to the "EMCO" approach

# Change in response to PDR (5/20/03)—No.1

## Action Item # PDR-4: Coax negative margin

The RG178 coaxial cable used for the PMT signal output transformer operates beyond the manufacturers voltage rating.



It is possible to construct a transformer using a bifilar winding using silicone-insulated wire.

See a PowerPoint presentation:  
[toroid\\_alternative\\_design2.pdf](#)

# Change in response to PDR (5/20/03)—No.2

## Action Item # PDR-17: Conformal coating

- One of the open items needed to be closed for procurement
- Requirement was “hacked away” at Zeuthen meeting earlier this year
- Efficient way to avoid trouble from dust, finger prints, etc.
- May be compatible with board wash
- Recommend keeping this requirement

# Changes as a result of (Iseg→EMCO)

Terminology change and document re-organization

PMT Modular HV Power Supply (9000-9939-02)

HV Control Board

Digital Interface

HV Generator

PMT HV Base Board

The Modular HV Power Supply consists of two boards (three possible component sources)

1<sup>st</sup> Dynode voltage scales with Cathode-Anode voltage (~40%)



# Specifications Review


# PMT HV Base Board

- 150M $\Omega$  total resistance
- Capacitor between each dynode interval
- Toroidal transformer for output
  
- EMCO 9731 has been evaluated with favorable results
- Needs a minor correction
- Needs layout improvement
- Needs some circuit improvement

[BLEEDER1x.pdf](#)


# HV Control Board

- Implements the same interface as the Iseg board
- Same ADC, DAC as the Iseg board
- Carries the HV generator
- No HV traces on control board



# HV Control Board

Schematic: [HV\\_MODULE\\_B\\_sch.pdf](#)



# HV Generator

Proposed spec changes:

Change **PROG** range from 0..4095V to 0..2047V

→ Eliminates x 2 OP-AMP

Change **MON** range from 0..4095V to 0..2047V

→ Eliminate 0..4096V REF

Change **output cable** from RG178/U to something else

→ Meet cable voltage rating

Eliminate “GAIN ADJUST” **trim pot**

→ No need for true 12-bit accuracy

→ Overall simplicity and increased reliability

# Conclusion

## ☐PMT HV Base Board

Needs a few technical decisions to move on:

Toroidal transformer specification

Conformal coating

Needs to choose a supplier

## ☐HV Control Board

Satisfactory prototype design

To be supplied by UW-Madison

## ☐HV Generator

Minor specification changes to be made

In contact with one vendor